

IECEx Certificate of Conformity

| INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres for rules and details of the IECEx Scheme visit www.iecex.com | | | | | |
|--|---|---|----------------------|--|--|
| Certificate No.: | IECEx ITS 14.0065X | Page 1 of 3 | Certificate history: | | |
| Status: | Current | Issue No: 0 | | | |
| Date of Issue: | 2015-06-11 | | | | |
| Applicant: | Teledyne Analytical Instruments Inc. 16830 Chestnut Street City of Industry California 91748. USA United States of America | | | | |
| Equipment: | Model 4000 Series – Purge Analyser | | | | |
| Optional accessory: | | | | | |
| Type of Protection: | Ех р | | | | |
| Marking: | Ex pxb IIC T* Gb | | | | |
| | IECEx ITS 14.0065X | | | | |
| | *See equipment description for T-Class de | etails | | | |
| Approved for issue of | on behalf of the IECEx | D G Bosson | | | |
| Certification Body: | | | | | |
| Position: | | Certification Officer | | | |
| Signature: (for printed version) | | | | | |
| Date: | | | | | |
| 2. This certificate is | nd schedule may only be reproduced in full. s not transferable and remains the property o authenticity of this certificate may be verified | of the issuing body. by visiting www.iecex.com or use of this QR Code. | | | |
| Certificate issue | d by: | | | | |
| Intertek Testing ITS House, Clea Leatherhead | & Certification Limited eve Road | Inter | tek | | |

Leatherhead Surrey, KT22 7SB United Kingdom



IECEx Certificate of Conformity

| Certificate No.: | IECEx ITS 14.0065X | Page 2 of 3 |
|--|---|---|
| Date of issue: | 2015-06-11 | Issue No: 0 |
| Manufacturer: | Teledyne Analytical Instruments Inc. 16830 Chestnut Street City of Industry California 91748. USA United States of America | |
| Additional manufacturing locations: | | |
| the IEC Standard list assessed and found t | ed as verification that a sample(s), representative of production, below and that the manufacturer's quality system, relating to the o comply with the IECEx Quality system requirements.This certi s, IECEx 02 and Operational Documents as amended | Ex products covered by this certificate, was |
| STANDARDS : The equipment and a to comply with the foll | ny acceptable variations to it specified in the schedule of this ce owing standards | rtificate and the identified documents, was found |
| IEC 60079-0:2011 Edition:6.0 | Explosive atmospheres - Part 0: General requirements | |
| IEC 60079-2:2014-07 Edition:6 | ' Explosive atmospheres - Part 2: Equipment protection by pres | surized enclosure "p" |
| | This Certificate does not indicate compliance with safety an other than those expressly included in the Stand | |
| TEST & ASSESSME A sample(s) of the eq | NT REPORTS: uipment listed has successfully met the examination and test re | quirements as recorded in: |
| Test Report: | | |
| GB/ITS/ExTR15.0026 | 5/00 | |
| Quality Assessment F | Report: | |
| GB/BAS/QAR12.0008 | 3/01 | |
| | | |



IECEx Certificate of Conformity

Certificate No.: IECEx ITS 14.0065X
Date of issue: 2015-06-11

Page 3 of 3

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Equipment performs Hydrocarbon Analysis in gases and liquids utilizing Flame Ionization Detection technology. The purged enclosure is constructed from cold rolled steel or 316 stainless steel and is approximately 36"x30"x36". The enclosure incorporates a Ex e certified window which is 13"x8".Purge is controlled with the Pepperl+ Fuchs Purge system (IECEx UL 08.0003x) and can be supplied with either Air when in continuous dilution mode or Nitrogen when utilizing leakage compensation. The temperature classification of the purged enclosure as covered in scope of this certification is T4. For clarity, the equipment can also be marked as T3 to reflect the use of certified equipment installed externally from the purge enclosure, which fall out of the scope of this certificate. Models covered by this certification are:

- · 4080/4020
- · 4080/4030
- . 4080/4040
- · 4080/4060
- · 4020B
- · 4030B
- · 4040B
- · 4060B

The enclosure has the following purge parameters. Minimum Purge Flow Rate 140SLPM N2 or Air

| Minimum Purge Duration 13 minute | S | |
|-----------------------------------|--------------------|----------------------|
| Enclosure min. overpressure | 1.2 mbar | |
| Enclosure max. overpressure | 13 mbar | |
| Supply min overpressure | 3 bar | |
| Supply max overpressure | 5 bar | |
| Maximum leakage rate | 25% | |
| Category of internal release | | |
| Limited Maximum release flow rate | H2 380 SCCM @ 2bar | CH4 1.5 SLPM @ 2 bar |

SPECIFIC CONDITIONS OF USE: YES as shown below:

- The end user must supply a flow restriction device that limits the flow to the containment system as follows: i. H2 to 380 SCCM at 2 BarG max ii. CH4 to 1.5 SLPM at 2 BarG max
- Temperatures at the cable entry point could exceed 70°C and 80°C at the branching point. Selection of cable must be appropriate for the ambient temperature range.
- Refer to drawing number D91840 for correct replacement of cable entries.
- The manufacturers operating and maintenance instructions shall always be followed.

Annex:

Annex to Annex to IECEx ITS 14.0065X issue 0.pdf



Schedule of Drawings for Certificate: IECEx ITS 14.0065X Issue 0

Manufacturer:

Teledyne Analytical Instruments Inc. 16830 Chestnut Street, City of Industry, California 91748. USA

Conditions of manufacture:

- Functional test of safety devices shall be verified and recorded.
- Leakage test shall be carried out in accordance with EN 60079-2:2007 clause 16.2 and recorded.
- The containment system shall be tested in accordance with EN 60079-2:2007 clause 16.7 and results recorded.
- Label must stipulate the worst case temperature classification with regards to the specific component utilized.

| Title | Drawing No.: | Rev. Level: | Date: |
|--|--------------|-------------|----------|
| OUTLINE DIAGRAM STRIPPER UNIT MODEL 4080/ 4000 SERIES (SHEETS 1 TO 5) | D- 91840 | 3 | 05/14/15 |
| TOXIC/FLAMMABLE LIQUIDS/GASES ENCLOSURE DANGER TAG | B- 64496 | 2 | 6-15-95 |
| PIPING DIAGRAM LHC ANALYSIS SYSTEM MODEL 4080/4020, ATEX CERT | C- 91839 | 1 | 08/07/14 |
| TAG DETAIL WARNING LABEL ASPHYXIATION RISK | B- 86356 | 0 | 11/04/11 |
| TAG DETAIL WARNING LABEL PRESSURIZED ENCLOSURE | B- 86355 | 0 | 11/04/11 |
| WIRING DIAGRAM STRIPPER/ ANALYSIS SYSTEM MODEL 4080/ 4020 (SHEETS 1 TO 6) | D- 91842 | 3 | 11/20/14 |

Intertek Testing & Certification Limited Intertek House, Cleeve Road, Leatherhead, Surrey, KT22 7SB Tel: +44 (0)1372 370900 Fax: +44 (0)1372 370977 <u>http://www.intertek.com</u> Registered No 3272281. Registered Office: Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ

This certificate may only be reproduced in its entirety and without change, schedule included and is subject to Intertek Testing & Certification Conditions for granting certification.